

# DECLARATION OF PERFORMANCE (Ref: 0086-CPR-781815)



18

Automatic opening smoke and heat  
ventilator, R016 Snowwhite  
Intended use for smoke and heat  
exhaust ventilation on flat and / or  
inclined roofs



Unique identification as per order number.

Velux Commercial Xtralite, Spencer Road, Blyth Riverside Business Park, Blyth, NE24 5TG

Essential Characteristic	Performance	AVCP	hEN
Aerodynamic free area	Cv=0.40 (Annex B, B1)	System 1	EN 12101-2:2003
Reliability: Smoke / Natural	Re 1000 / 10,000		
Snow load	SL 500		
Low ambient temperature	T (-15)		
Wind Load	WL 1500		
Resistance to heat	B 300		
Reaction to fire	F		

Notified body: BSI UK (0086)

Test reports: 8P04882-01 dated 17/07/2018, 0402-CPR-SC1219-13 dated 21/08/2018 issue 4

The performance of the products identified with the above identification codes are in conformity with the relevant declared performances.

Factory production control requirements are assessed by the Notified Body. There are no dangerous substances in the product.

This declaration of performance is issued under the sole responsibility of the manufacturer Xtralite (Rooflights) Ltd.

Signed for and on behalf of the manufacturer by:

Name and position: Steven Steele Technical Services Manager	Place & date of issue: Blyth, Northumberland, UK Date: 02.12.24	Signature: S Steele
---	---	------------------------